



# CLARK COUNTY FIRE DEPARTMENT

## Fire Hazard & Prevention Services

575 E. Flamingo Road, Las Vegas, NV 89119  
(702) 455-7316 FAX (702) 455-7347



**105.8.a.1**

- TITLE:** AEROSOL PRODUCTS REQUIREMENTS GUIDELINES
- SCOPE:** Storage, handling and retail display of Level 2 or Level 3 aerosol products with aggregate amounts in excess of 500 pounds net weight shall comply with Article 88 of the 2005 Clark County Fire Code.
- PURPOSE:** To standardize fire department requirements relating to the classification and permitting of storage or display of aerosol products.

### SPECIFICATIONS AND REQUIREMENTS

At the time of permit application, three (3) sets of plans, drawn to an indicated scale, must be submitted for review and approval. Permit fees for this type of submittal vary. The standard permit fee is due upon submittal. Please see the **Clark County Fire Department Permit and Service Fee Schedule** for specific information. Please check our website for plan status. Any additional fees will be indicated on the website. Once the plans have been approved and any outstanding fees have been paid, an inspection can be scheduled.

Our website is <http://www.accessclarkcounty.com/fire/firedept.htm> . To check on plan status, click on the "Plan Status" button and follow the instructions. To schedule an inspection, Click on "Services" in the teal strip on the top. On the left side under **Inspection** click on "Fire Inspection" and follow the instructions

### PLANS

Plans must include the name, address, and Assessors Parcel Number (APN) of the building and a business contact name and phone number.

A building floor plan drawn to an indicated scale, or dimensioned, shall include type of storage and/or display areas or cabinets within the building and shall indicate doorways, corridors, means of egress and evacuation routes.

When the aerosol product classification is unknown the contents shall be treated as Level 3 Aerosol. The manufacturers Material Safety Data Sheets (MSDS) shall identify the classification level of each aerosol product. (NFPA 30B).

Indicate type of construction, height and bracing of shelves.

Fire protection systems (if any) in building.

Indicate storage arrangement (pallets, or solid pile).

Indicate other commodities stored or on display in building.

Storage of aerosol products may require approval of the building by the Clark County Department of Developmental Services, contact the Clark County Fire Prevention Bureau at 455-7100 for additional information.