



CLARK COUNTY FIRE DEPARTMENT
Fire Prevention Bureau
575 E. Flamingo Road, Las Vegas, NV 89119
(702) 455-7316 FAX (702) 455-7347



105.8.1.1

TITLE: **LPG-TANKS OF 125 GALLON OR MORE WATER CAPACITY
(INCLUDES SINGLE FAMILY RESIDENCES)**

SCOPE: LPG tanks shall be installed in accordance with this guide 2005 Clark County Fire Code.

PURPOSE: To standardize fire department requirements relating to the installation and permitting of LPG tanks.

SPECIFICATIONS AND REQUIREMENTS:

At the time of permit application, three (3) sets of plans, drawn to an indicated scale, must be submitted for review and approval. The standard permit fee is due upon submittal. Please see the **Clark County Fire Department Permit and Service Fee Schedule** for specific information. Please check our website for plan status. Any additional fees will be indicated on the website. Once the plans have been approved and any outstanding fees have been paid, an inspection can be scheduled.

Our website is <http://www.accessclarkcounty.com/fire/firedept.htm>. To check on plan status, click on the "Plan Status" button and follow the instructions. To schedule an inspection, click on "Services" in the teal strip on the top. On the left side under **Inspection**, click on "Fire Inspection" and follow the instructions.

PLANS:

Include a site plan showing exact location of tank relative to property lines and structures. Include information on pressure relief valve and piping, gallonage of tank and tank serial number. Also, indicate location of dispensing equipment, if so equipped.

Include location/vicinity map with address or cross streets (if address has not been issued).

TECHNICAL DATA:

Copies of manufacturer's literature for tank(s) and dispensing equipment.

OTHER APPROVALS:

Clark County Building Department must approve and permit all gas lines/piping, appliances and appurtenances prior to installation and use of LPG.

INSPECTIONS:

Prior to filling and using LPG tanks, the Clark County Fire Department must be notified so an inspection can occur and our approval sticker will be applied if the installation is acceptable.

Our website is <http://www.accessclarkcounty.com/fire/firedept.htm>. The following will be required to schedule the inspection:

Location of project/address:

*Clark County Fire Department Permit number
Type of requested inspection (final LPG tank inspection)
Contact person and phone number.*

This will allow you to obtain final approval from the Clark County Building Department (if a permit is required from their office) and ultimately allow your tank to be filled and used.