



Clark County Fire Prevention

Mission Statement: "To provide the highest level of fire protection and related services"

TITLE: FIRE HYDRANT FLOW TEST

SCOPE: Flowing of fire hydrants shall be performed in accordance with this guideline and the 2005 Clark County Fire Code.

PURPOSE: To standardize fire department requirements relating to flow testing of fire hydrants.

SPECIFICATIONS AND REQUIREMENTS

All requests for fire hydrant flow tests must be submitted to this Department. A Fire Department permit fee (minimum \$75) is required at time of submittal. Permits are issued over the counter. Call 226-8991 to schedule an inspection.

Provide names of cross streets and approximate location of fire hydrants to be flowed in the space provided below.

Contractor is responsible for insuring test is conducted in a safe manner. Precautions must be taken to insure that no property is damaged as a result of the test.

On the site, the contractor must provide static gauge(s), Pitot gauge(s) and hydrant wrench(es). It is the responsibility of the contractor to connect gauges and open hydrants. A diffuser is required when flow test is being conducted adjacent to a street with a high degree of traffic or when damage to landscape could occur. Inspection staff is only responsible for witnessing the test and recording information.

REQUEST FOR FIRE HYDRANT FLOW TEST

CONTRACTOR: _____ **PH. NO.** _____

NAME OF PROJECT: _____

ADDRESS/LOCATION: _____

REASON FOR FIRE FLOW: _____

