



Clark County Fire Prevention

Mission Statement: "To provide the highest level of fire protection and related services"

105.8.f.7

TITLE: TEMPORARY (6 MONTHS OR LESS) DIESEL GENERATORS

SCOPE: Diesel generators, installed for a period of six (6) Months or less, shall be installed in accordance with this guide and with the 2005 Clark County Fire Code.

PURPOSE: To standardize fire department requirements relating to the installation and permitting of temporary diesel generators.

SPECIFICATIONS AND REQUIREMENTS

At the time of permit application, three (3) sets of plans, drawn to an indicated scale and legible, must be submitted for review and approval. Permit fees for this type of submittal vary. The standard permit fee is due upon submittal. Please see the Clark County Fire Department Permit and Service Fee Schedule for specific information. A minimum of three sets of plans need to be submitted. Please check our website for plan status. Any additional fees will be indicated on the website. Once the plans have been approved and any outstanding fees have been paid, an inspection can be scheduled.

Our website is <http://www.accessclarkcounty.com/fire/firedept.htm>. To check on plan status, click on the "Plan Status" button and follow the instructions. To schedule an inspection, Click on "Services" in the teal strip on the top. On the left side under **Inspection** click on "Fire Inspection" and follow the instructions.

PLANS

Name, physical address, and Assessors Parcel Number (APN) of the project must be included on the plans. Plans shall also designate the authority having jurisdiction. Plans must be drawn to an indicated scale or be suitably dimensioned and legible.

Specify that tank is UL# 142 or equivalent

Indicate quantities of Diesel to be stored.

Identify type of secondary containment

Provide site plan indicating **location of generator** in relation to **structures**, other tanks and to **property lines**. Also show **emergency vehicle access**, **fire appliances** (fire hydrants and/or fire extinguishers), **vehicle impact protection** (if located on a Road or Parking lot) and **fencing** (when used in conjunction with an assembly occupancy or temporary membrane structure).

TECHNICAL DATA

Submit copies of manufacturer's literature for auxiliary tank(s) & generator.