



Clark County Fire Prevention

Mission Statement: "To provide the highest level of fire protection and related services"



TITLE: Special Amusement Buildings Checklist

SCOPE: This checklist applies to any temporary or permanent building or portion thereof that is occupied for amusement or entertainment, so arranged that the means of egress is not readily apparent due to visual or audio distractions, such as, but not limited to haunted houses, carnivals or fairs.

Business Name _____ **Date** _____

Address _____

1. Plans submitted to CCFD for review and approval are drawn to a specified scale and include:
 - _____ Path of egress.
 - _____ Fire Exits.
 - _____ Illuminated exit signs at 8" and 7' levels.
 - _____ Location, size and type of fire extinguishers.
 - _____ Location of emergency generators and temporary wiring.
 - _____ Location of smoke detectors.
 - _____ Buildings of 1,000 square feet or larger require automatic fire sprinklers, installed by a contractor licensed by the Nevada State Fire Marshal Office.

2. Conduct a 'pre-test' of emergency procedures with employees to assure systems operate as designed:
 - _____ Activation of any approved device sends an alarm to a constantly attended location in the building.
 - _____ Public address system is audible through out the building.
 - _____ Activation of two or more approved devices **automatically:**
 - _____ Stops confusing sounds and other visual effects
 - _____ Activates an approved directional exit marking and
 - _____ Illuminates the means of egress with a light of not less than 1-foot candle-power at the walking surface.

3. Copies of paperwork needed for CCFD fire inspectors review:
 - _____ CCFD permit application and this checklist.
 - _____ Copy of written emergency procedures and 'pre-test' results.
 - _____ Documentation showing all decorative materials have been rendered flame resistant.

4. _____ Employees have been provided with working flashlights for emergency lighting.

After review of emergency procedures, personnel shall sign and date below. Use reverse if necessary. Maintain this report at the work site, available for review by CCFD personnel. Signature implies agreement to follow emergency procedures and CCFD guidelines.

